

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Inspection satisfactory

Email Address(es): tequigley@dadeschools.net;
dugasmarier@dadeschools.net;
MWVertz@dadeschools.net;
IPalacio@dadeschools.net;
wcabrera@dadeschools.net;

Violations Comments

Violation #5. Maintenance & Repair
At the time of inspection observed handwash sink loose. Repair or replace handwash sink

At the time of inspection observed at classroom 005 A.C no working . Repair air conditioner

At the time of inspection observed at classrrom 020 one missing light bulb (60 Ft). Replace light bulb .

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #9. Mechanical Ventilation
At the time of inspection observed at girls' room # 026 mechanical ventilation with dust like substances

At the time of inspection observed at boys room # 025 mechanical ventilation with dust like substances

CODE REFERENCE: 9. Mechanical Ventilation. 5(16)(a)2 SREF. Mechanical ventilation systems shall be maintained in an operable condition at all times. 5(16)(a)4 SREF. Exhaust systems from toilet rooms, custodial closets, shower and locker rooms, athletic equipment rooms, etc., shall be maintained in an operable condition at all times. 5(13)(g)1.d SREF. Toilet rooms shall have exhaust fans vented to the exterior. 5(16)(a)10 SREF. Stationary local sources producing air-borne particulates, heat, odors, fumes, spray, vapors, smoke or gases in such quantities as to be irritating or injurious to human health shall have an exhaust system to collect and remove the contaminants. Such exhaust shall discharge directly to the exterior of the building. 468.3.6.2 FBC and 468.3.6.3 FBC. Kiln rooms and areas shall be provided with adequate exhaust to dispel emitted heat to the exterior, and they shall not be connected to any other exhaust system. 5(16)(a)5 SREF. Science laboratory fume hoods and laboratory emergency fans shall be maintained in an operable condition. 468.3.6.4 FBC. HVAC systems in chemistry labs and science classrooms shall be designed and installed to ensure that chemicals originating from the space are not recirculated. 468.3.6.5 SREF. Rooms used for the storage, handling, and disposal of chemicals used in school, college, and university laboratories shall be vented to the exterior. The ventilation system shall not be connected to the air conditioning return air system.

Inspection Conducted By: Alexander Olaya (67699)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 6/26/2023

Inspector Signature:

Handwritten signature of Alexander Olaya.

Client Signature:

Handwritten signature of Gratigny El.